

# Quadro di risultati

## QUADRO DI RISULTATI

### Feeder (Alimentazione principale)

Feeder

Feeder

Descrizione	Fase	Simult.	Pot. Calc. (W)	Pot. Ist. (W)	Pot. Ric. (W)	cos φ	Lung. (m)	Sezione (mm)	Isol.	Met. Inst.	I <sub>b</sub> (A)	I <sub>z</sub> (A)	ΔU (%)	ΔU <sub>sc</sub> (%)	Canaliz. (mm)
Feeder	F+N	-	5773.50	20010.00	5773.50	1.00	15.00	Cu 450/750 V Poliolefine termoplastiche (Z1) 3(1x6)	450/750 V	B1	25.00	35.67	1.22	-	Senza canale
c1	F+N	1.00	2300.00	2300.00	2300.00	1.00	10.00	Cu 450/750 V Polivinilcloruro (PVC) 3(1x1.5)	450/750 V	B1	9.96	15.23	1.29	-	Tubo 15 mm
c2	F+N	1.00	3680.00	3680.00	3680.00	1.00	10.00	Cu 450/750 V Polivinilcloruro (PVC) 3(1x2.5)	450/750 V	B1	15.93	20.88	1.24	-	Tubo 15 mm
c3	F+N	1.00	5750.00	5750.00	5750.00	1.00	10.00	Cu 450/750 V Polivinilcloruro (PVC) 3(1x6)	450/750 V	B1	24.90	35.67	0.81	-	Tubo 15 mm
c4	F+N	1.00	4600.00	4600.00	4600.00	1.00	10.00	Cu 450/750 V Polivinilcloruro (PVC) 3(1x4)	450/750 V	B1	19.92	27.84	0.97	-	Tubo 15 mm
c5	F+N	1.00	3680.00	3680.00	3680.00	1.00	10.00	Cu 450/750 V Polivinilcloruro (PVC) 3(1x2.5)	450/750 V	B1	15.93	20.88	1.24	-	Tubo 15 mm

Descrizione	I <sub>B</sub> (A)	I <sub>n</sub> (A)	I <sub>z</sub> (A)	I <sub>CCmax</sub> (A)	Pdi (kA)	I <sub>CCmin</sub> (A)	I <sub>m</sub> (kA)	I <sub>d</sub> (A)	Sens.dif. (mA)
Feeder	25.00	25.00	35.67	8.05	20.00	2.43	0.11	-	-
c1	9.96	10.00	15.23	3.53	4.50	0.81	0.10	9.17	30
c2	15.93	16.00	20.88	3.53	4.50	1.10	0.16	9.19	30
c3	24.90	25.00	35.67	3.53	4.50	1.61	0.25	9.20	30
c4	19.92	20.00	27.84	3.53	4.50	1.38	0.20	9.20	30
c5	15.93	16.00	20.88	3.53	4.50	1.10	0.16	9.19	30